



**ASBESTOS
SPECIALISTS,
INC.**

Post Office Box 368
Linthicum Heights, MD 21090-0368

(410) 796-5379
Fax (410) 796-2849

Thursday, May 26, 2011

The Whiting-Turner Contracting Co.
7475 Wisconsin Ave., Suite 400
Bethesda, MA 20814

RE: Lead Air Sample Results, Maryland Institute College of Arts

Dear Mr. Eric Hartlove,

The following table contains the results of the lead air samples which were collected by a representative of Asbestos Specialists, Inc. at the Maryland Institute College of Arts and submitted to EMSL Analytical, Inc. EMSL Analytical, Inc. analyzed the samples and the results are in the table below.

Date	Sample	Sample Location	Volume	Concentration
5-16-11	01	Juan Argueta 2 nd Floor North	600	< 6.7 ug/m ³
5-16-11	02	Work Area 2 nd Floor North	960	< 4.2 ug/m ³
5-16-11	03	Perimeter 2 nd Floor North	960	< 4.2 ug/m ³
5-17-11	04	Miguel Mejia 2 nd Floor South	600	< 6.7 ug/m ³
5-17-11	05	Work Area 2 nd Floor South	960	< 4.2 ug/m ³
5-17-11	06	Perimeter 2 nd Floor South	960	< 4.2 ug/m ³
5-23-11	07	Juan Argueta 2 nd Floor South	600	< 6.7 ug/m ³
5-23-11	08	Work Area 2 nd Floor South	960	< 4.2 ug/m ³
5-23-11	09	Perimeter 2 nd Floor South	960	< 4.2 ug/m ³

If you have any questions or concerns, you may reach us at 410-796-5379.

Sincerely,

David Whitten
Safety Coordinator



EMSL Analytical, Inc.

10768 Baltimore Avenue, Beltsville, MD 20705

Phone: (301) 937-5700 Fax: (301) 937-5701 Email: beltsvillelab@emsl.com

Attn: David Whitten
Asbestos Specialist Inc.
7585 Washington Blvd.
Suite 104
Baltimore, MD 21075

Customer ID: ASPC30
Customer PO:
Received: 05/26/11 11:15 AM
EMSL Order: 191104923

Fax: (410) 796-2849 Phone: (410) 796-5379
Project: MICA

EMSL Proj:

Test Report: Lead in Air by Flame AAS (NIOSH 7082)

Table with 7 columns: Client Sample Description, Lab ID, Collected, Analyzed, Volume, Lead Concentration. Contains 9 rows of sample data with lead concentrations ranging from <4.2 to <6.7 µg/m³.

Initial report from 05/26/2011 15:21:53

Handwritten signature of Joe Centifonti

Joe Centifonti, Laboratory Manager
or other approved signatory

Reporting limit is 4 µg/filter. OSHA PEL - 50 µg/m³, OSHA action level - 30 µg/m³. The QC data associated with the sample results included in this report meet the recovery and precision requirements established by the AIHA, unless specifically indicated otherwise in the comment section. Unless otherwise noted, results in this report are not blank corrected. The Laboratory is not responsible for data reported in µg/m³ which is dependent on volume collected by non-laboratory personnel. This report may not be reproduced except in full, without written approval by EMSL. This report relates only to those items tested. Samples received in good condition unless otherwise noted. Quality Control Data associated with this sample set is within acceptable limits, unless otherwise noted

Samples analyzed by EMSL Analytical, Inc. Beltsville, MD A2LA Accredited Environmental Testing Cert #2845.02